

PINAMUNGAJAN WATER DISTRICT
SUMMARY REPORT ON MICROBIOLOGICAL TEST
MONTH OF JANUARY 2017

1) Population actually served by utility _____ 26,585
 (No. of service connections (5,137 x 5) average no. of persons
 per service connection)

2) Required minimum number of sample _____ 5
 (Based on the following table)

Population Served	Minimum Frequency of sampling
Less than 5,000	One (1) sample monthly
5,000 – 100,000	One (1) sample per 5000 population monthly
More than 100,000	20 samples plus 1 sample per 10,000 population monthly

AND
FLU

3) Sample Requirement
 a. No. of samples examined _____ 10
 b. Percent (%) to the minimum required _____ 200%
 c. Meets Standard / Yes No
 (If b is 100% or more, check Yes)

4) Method
 4.1 Multiple Tube Fermentation Technique (MTFT)
 a. Number of samples showing presence of coli form colonies _____ 0
 b. Percent (%) to samples examined (4.1.a/3.a x 100) _____ 0%
 c. Meets Standard / Yes No
 (If b is 5% or less, check Yes)

4.2 Membrane Filter Technique (MFT)
 a. Number of samples showing presence of coli form colonies _____ NA
 b. Percent (%) to the total number of
 samples analyzed (4.2.a/3.a x 100) _____ NA
 c. Meets Standard Yes No
 (If b is 5% or less, check Yes)

4.3 Fecal Coli form Test (FCT)
 a. Number of samples showing presence of fecal coli form
 organisms with MPN/100 ml value of 1.1 or more _____ 0
 b. Meets Standard / Yes No
 (If a is Zero, check Yes)

4.4 Heterotrophic Plate Count (HPC)
 a. Number of HPC tests conducted _____ 10
 b. Number of Samples showing HPC value <500 CFU/ml _____ 10
 c. Percent (%) to the number of tests conducted (b/a x 100) _____ 100%
 d. Meets Standard / Yes No
 (If c is 100%, check Yes)

Attached are the corresponding laboratory test results.

SUBMITTED BY:

[Signature]
 NEMFA P. TUNDAG
 General Manager

March 28, 2017
 Date

Received by:

[Signature]
 BERNADETTE B. ATU
 Rural Health Unit
[Signature] LBC

LWUA

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Name of Client: Pinamungajan Water District
Name of Company: Pinamungajan Water District
Water Treated: Yes
Sampling Point/s: Faucet - Rebecca Siarot
Submitted by: Nemfa Tundag
Date Received: January 27, 2017
Date of Sampling: January 27, 2017
Time of Sampling: 11:20 a.m.
Place of Sampling: Targetan, Pinamungajan, Cebu
Water Supply: Deepwell
Date of Release: February 3, 2017

RWT No. : ML 78790

Test Requested	Methodology	Units of Measurement/ Standards	No. of Positive Tubes (out of 5 Tubes)	Result/s	Standard/s	Remarks
Total Coliform	MTFT	MPN/100 mL	0	< 1.1	< 1.1	Passed
Thermotolerant Coliform	MTFT	MPN/100 mL	0	< 1.1	< 1.1	Passed
Heterotrophic Plate Count	Pour Plate	CFU/ mL	-	< 1	< 500	Passed

* MTFT - Multiple Tube Fermentation Technique

* CFU - Colony Forming Unit

* MPN - Most Probable Number

The result given in this report were obtained at the time of the test and refer only to the particular sample submitted.

References:

Philippine National Standards for Drinking Water, 2007.
Department of Health.
DAO 34 - 35. Department of Environment and Natural Resources.
American Public Health Association (APHA), 2005.
Standard Methods for the Examination of Water and Wastewater,
21st ed., APHA Washington D.C.

Analysis done by:

Ms. Sherry Lyn Segueria
Lab Analyst

Checked & Certified by:

Ms. Happy Mariel U. Lim
Laboratory Head
PRC License No. 0013262

Approved by:

Fr.
Mr. John Jay L. Po
General Manager

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Name of Client: Pinamungajan Water District
Name of Company: Pinamungajan Water District
Water Treated: Yes
Sampling Point/s: Faucet - Joel Sablas
Submitted by: Nemfa Tundag
Date Received: January 27, 2017
Date of Sampling: January 27, 2017
Time of Sampling: 10:22 a.m.
Place of Sampling: Tanibag, Pinamungajan, Cebu
Water Supply: Deepwell
Date of Release: February 3, 2017

RWT No. : ML 78790

Test Requested	Methodology	Units of Measurement/ Standards	No. of Positive Tubes (out of 5 Tubes)	Result/s	Standard/s	Remarks
Total Coliform	MTFT	MPN/100 mL	0	< 1.1	< 1.1	Passed
Thermotolerant Coliform	MTFT	MPN/100 mL	0	< 1.1	< 1.1	Passed
Heterotrophic Plate Count	Pour Plate	CFU/ mL	-	< 1	< 500	Passed

* MTFT - Multiple Tube Fermentation Technique

* CFU - Colony Forming Unit

* MPN - Most Probable Number

The result given in this report were obtained at the time of the test and refer only to the particular sample submitted.

References:

Philippine National Standards for Drinking Water, 2007.
Department of Health.
DAO 34 - 35. Department of Environment and Natural Resources.
American Public Health Association (APHA), 2005.
Standard Methods for the Examination of Water and Wastewater,
21st ed., APHA Washington D.C.

Analysis done by:

Ms. Sherry Lyn Seguererra
Lab Analyst

Checked & Certified by:

Ms. Happy Mariel U Lim
Laboratory Head

PRC License No. 0013262

Approved by:

Mr. Johnjay L. Po
General Manager

Sangi Tabunok, Talisay City, Cebu • Tel. Nos.: (032) 272-7739 / 272-5186 / 491-7196

Accreditation No. 07-WL-2015-05-P

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Name of Client: Pinamungajan Water District
 Name of Company: Pinamungajan Water District
 Water Treated: Yes
 Sampling Point/s: Faucet - Babie Juromay
 Submitted by: Nemfa Tundag
 Date Received: January 27, 2017
 Date of Sampling: January 27, 2017
 Time of Sampling: 10:42 a.m.
 Place of Sampling: Tajao, Pinamungajan, Cebu
 Water Supply: Deepwell
 Date of Release: February 3, 2017

RWT No. : ML 78790

Test Requested	Methodology	Units of Measurement/ Standards	No. of Positive Tubes (out of 5 Tubes)	Result/s	Standard/s	Remarks
Total Coliform	MTFT	MPN/100 mL	0	< 1.1	< 1.1	Passed
Thermotolerant Coliform	MTFT	MPN/100 mL	0	< 1.1	< 1.1	Passed
Heterotrophic Plate Count	Pour Plate	CFU/ mL	-	< 1	< 500	Passed

* MTFT - Multiple Tube Fermentation Technique

* CFU - Colony Forming Unit

* MPN - Most Probable Number

The result given in this report were obtained at the time of the test and refer only to the particular sample submitted.

References:

Philippine National Standards for Drinking Water, 2007.
 Department of Health.
 DAO 34 - 35. Department of Environment and Natural Resources.
 American Public Health Association (APHA), 2005.
 Standard Methods for the Examination of Water and Wastewater,
 21st ed., APHA Washington D.C.

Analysis done by:

Ms. Sherry Lyn Segueria
 Lab Analyst

Checked & Certified by:

Ms. Happy Mariel U. Lim
 Laboratory Head

Approved by:

Mr. Johnjay L. Po
 General Manager

Sangi Tabunok, Talisay City, Cebu • Tel. Nos.: (032) 272-7739 / 272-5186 / 491-7196

Accreditation No. 07-WL-2015-05-P

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Name of Client: Pinamungajan Water District
Name of Company: Pinamungajan Water District
Water Treated: Yes
Sampling Point/s: Faucet - Lucebella Cantutay
Submitted by: Nemfa Tundag
Date Received: January 27, 2017
Date of Sampling: January 27, 2017
Time of Sampling: 8:51 a.m.
Place of Sampling: Sacsac, Pinamungajan, Cebu
Water Supply: Deepwell
Date of Release: February 3, 2017

RWT No. : ML 78790

Test Requested	Methodology	Units of Measurement/ Standards	No. of Positive Tubes (out of 5 Tubes)	Result/s	Standard/s	Remarks
Total Coliform	MTFT	MPN/100 mL	0	< 1.1	< 1.1	Passed
Thermotolerant Coliform	MTFT	MPN/100 mL	0	< 1.1	< 1.1	Passed
Heterotrophic Plate Count	Pour Plate	CFU/ mL	-	< 1	< 500	Passed

* MTFT - Multiple Tube Fermentation Technique

* CFU - Colony Forming Unit

* MPN - Most Probable Number

The result given in this report were obtained at the time of the test and refer only to the particular sample submitted.

References:

Philippine National Standards for Drinking Water, 2007.
Department of Health.
DAO 34 - 35. Department of Environment and Natural Resources.
American Public Health Association (APHA)., 2005.
Standard Methods for the Examination of Water and Wastewater,
21st ed., APHA Washington D.C.

Analysis done by:

Ms. Sherry Lyn Seguererra
Lab Analyst

Checked & Certified by:

Ms. Happy Mariel U. Lim
Laboratory Head

PRC License No. 0013262

Approved by:

Mr. Johnjay L. Po
General Manager

Sangi Tabunok, Talisay City, Cebu • Tel. Nos.: (032) 272-7739 / 272-5186 / 491-7196

Accreditation No. 07-WL-2015-05-P

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Name of Client: Pinamungajan Water District
Name of Company: Pinamungajan Water District
Water Treated: Yes
Sampling Point/s: Faucet - Edgardo Lingaolingao
Submitted by: Nemfa Tundag
Date Received: January 27, 2017
Date of Sampling: January 27, 2017
Time of Sampling: 9:31 a.m.
Place of Sampling: Poblacion, Pinamungajan, Cebu
Water Supply: Deepwell
Date of Release: February 3, 2017

RWT No. : ML 78790

Test Requested	Methodology	Units of Measurement/ Standards	No. of Positive Tubes (out of 5 Tubes)	Result/s	Standard/s	Remarks
Total Coliform	MTFT	MPN/100 mL	0	< 1.1	< 1.1	Passed
Thermotolerant Coliform	MTFT	MPN/100 mL	0	< 1.1	< 1.1	Passed
Heterotrophic Plate Count	Pour Plate	CFU/ mL	-	< 1	< 500	Passed

* MTFT - Multiple Tube Fermentation Technique

* CFU - Colony Forming Unit

* MPN - Most Probable Number

The result given in this report were obtained at the time of the test and refer only to the particular sample submitted.

References:

Philippine National Standards for Drinking Water, 2007.
Department of Health.
DAO 34 - 35. Department of Environment and Natural Resources.
American Public Health Association (APHA), 2005.
Standard Methods for the Examination of Water and Wastewater,
21st ed., APHA Washington D.C.

Analysis done by:

Ms. Sherry Lynn Segueria
Lab Analyst

Checked & Certified by:

Ms. Happy Mariel U. Lim
Laboratory Head

PRC License No. 0013262

Approved by:

Mr. John Jay L. Po
General Manager

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Name of Client: Pinamungajan Water District
Name of Company: Pinamungajan Water District
Water Treated: Yes
Sampling Point/s: Faucet - Michelle Jane Marinduque
Submitted by: Nemfa Tundag
Date Received: January 27, 2017
Date of Sampling: January 27, 2017
Time of Sampling: 9:02 a.m.
Place of Sampling: Pandacan, Pinamungajan, Cebu
Water Supply: Deepwell
Date of Release: February 3, 2017

RWT No. : ML 78790

Test Requested	Methodology	Units of Measurement/ Standards	No. of Positive Tubes (out of 5 Tubes)	Result/s	Standard/s	Remarks
Total Coliform	MTFT	MPN/100 mL	0	< 1.1	< 1.1	Passed
Thermotolerant Coliform	MTFT	MPN/100 mL	0	< 1.1	< 1.1	Passed
Heterotrophic Plate Count	Pour Plate	CFU/ mL	-	< 1	< 500	Passed

* MTFT - Multiple Tube Fermentation Technique

* CFU - Colony Forming Unit

* MPN - Most Probable Number

The result given in this report were obtained at the time of the test and refer only to the particular sample submitted.

References:

Philippine National Standards for Drinking Water, 2007.
Department of Health.
DAO 34 - 35. Department of Environment and Natural Resources.
American Public Health Association (APHA)., 2005.
Standard Methods for the Examination of Water and Wastewater,
21st ed., APHA Washington D.C.

Analysis done by:

Ms. Sherry Lynn Segueria
Lab Analyst

Checked & Certified by:

Ms. Happy Mariel U. Lim
Laboratory Head

PRC License No. 0013262

Approved by:

Mr. John Jay L. Po
General Manager

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Name of Client: Pinamungajan Water District
Name of Company: Pinamungajan Water District
Water Treated: Yes
Sampling Point/s: Faucet - Marciana Tellidua
Submitted by: Nemfa Tundag
Date Received: January 27, 2017
Date of Sampling: January 27, 2017
Time of Sampling: 8:31 a.m.
Place of Sampling: Mangoto, Pinamungajan, Cebu
Water Supply: Deepwell
Date of Release: February 3, 2017

RWT No. : ML 78790

Test Requested	Methodology	Units of Measurement/ Standards	No. of Positive Tubes (out of 5 Tubes)	Result/s	Standard/s	Remarks
Total Coliform	MTFT	MPN/100 mL	0	< 1.1	< 1.1	Passed
Thermotolerant Coliform	MTFT	MPN/100 mL	0	< 1.1	< 1.1	Passed
Heterotrophic Plate Count	Pour Plate	CFU/ mL	-	2	< 500	Passed

* MTFT - Multiple Tube Fermentation Technique

* CFU - Colony Forming Unit

* MPN - Most Probable Number

The result given in this report were obtained at the time of the test and refer only to the particular sample submitted.

References:

Philippine National Standards for Drinking Water, 2007.
Department of Health.
DAO 34 - 35. Department of Environment and Natural Resources.
American Public Health Association (APHA), 2005.
Standard Methods for the Examination of Water and Wastewater,
21st ed., APHA Washington D.C.

Analysis done by:

Ms. Sherry Lyn Segueria
Lab Analyst

Checked & Certified by:

Ms. Happy Mariel U. Lim
Laboratory Head
PRC License No. 0013262

Approved by:

Mr. John Jay L. Po
General Manager

Sangi Tabunok, Talisay City, Cebu • Tel. Nos.: (032) 272-7739 / 272-5186 / 491-7196

Accreditation No. 07-WL-2015-05-P

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Name of Client: Pinamungajan Water District
Name of Company: Pinamungajan Water District
Water Treated: Yes
Sampling Point/s: Faucet - Arsenio Undalok
Submitted by: Nemfa Tundag
Date Received: January 27, 2017
Date of Sampling: January 27, 2017
Time of Sampling: 10:01 a.m.
Place of Sampling: Butong, Pinamungajan, Cebu
Water Supply: Deepwell
Date of Release: February 3, 2017

RWT No. : ML 78790

Test Requested	Methodology	Units of Measurement/ Standards	No. of Positive Tubes (out of 5 Tubes)	Result/s	Standard/s	Remarks
Total Coliform	MTFT	MPN/100 mL	0	< 1.1	< 1.1	Passed
Thermotolerant Coliform	MTFT	MPN/100 mL	0	< 1.1	< 1.1	Passed
Heterotrophic Plate Count	Pour Plate	CFU/ mL	-	< 1	< 500	Passed

* MTFT - Multiple Tube Fermentation Technique

* CFU - Colony Forming Unit

* MPN - Most Probable Number

The result given in this report were obtained at the time of the test and refer only to the particular sample submitted.

References:

Philippine National Standards for Drinking Water, 2007.
Department of Health.
DAO 34 - 35. Department of Environment and Natural Resources.
American Public Health Association (APHA), 2005.
Standard Methods for the Examination of Water and Wastewater,
21st ed., APHA Washington D.C.

Analysis done by:

Ms. Sherry Lynn Segueria
Lab Analyst

Checked & Certified by:

Ms. Happy Mariel U. Lim
Laboratory Head

PRC License No. 0013262

Approved by:

Mr. Johnjay L. Po
General Manager

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Name of Client: Pinamungajan Water District
Name of Company: Pinamungajan Water District
Water Treated: Yes
Sampling Point/s: Faucet - Pelagia Deroy
Submitted by: Nemfa Tundag
Date Received: January 27, 2017
Date of Sampling: January 27, 2017
Time of Sampling: 8:17 a.m.
Place of Sampling: Binabag, Pinamungajan, Cebu
Water Supply: Deepwell
Date of Release: February 3, 2017

RWT No. : ML 78790

Test Requested	Methodology	Units of Measurement/ Standards	No. of Positive Tubes (out of 5 Tubes)	Result/s	Standard/s	Remarks
Total Coliform	MTFT	MPN/100 mL	0	< 1.1	< 1.1	Passed
Thermotolerant Coliform	MTFT	MPN/100 mL	0	< 1.1	< 1.1	Passed
Heterotrophic Plate Count	Pour Plate	CFU/ mL	-	< 1	< 500	Passed

* MTFT - Multiple Tube Fermentation Technique

* CFU - Colony Forming Unit

* MPN - Most Probable Number

The result given in this report were obtained at the time of the test and refer only to the particular sample submitted.

References:

Philippine National Standards for Drinking Water, 2007.
Department of Health.
DAO 34 - 35. Department of Environment and Natural Resources.
American Public Health Association (APHA), 2005.
Standard Methods for the Examination of Water and Wastewater,
21st ed., APHA Washington D.C.

Analysis done by:

Ms. Sherry Lyn Segueria
Lab Analyst

Checked & Certified by:

Ms. Happy Mariel U. Lim
Laboratory Head
PRC License No. 0013262

Approved by:

Mr. Johnjay L. Po
General Manager

Sangi Tabunok, Talisay City, Cebu • Tel. Nos.: (032) 272-7739 / 272-5186 / 491-7196

Accreditation No. 07-WL-2015-05-P

BACTERIOLOGICAL TEST RESULT FOR DRINKING WATER

Name of Client: Pinamungajan Water District
Name of Company: Pinamungajan Water District
Water Treated: Yes
Sampling Point/s: Faucet - Marianita Baste
Submitted by: Nemfa Tundag
Date Received: January 27, 2017
Date of Sampling: January 27, 2017
Time of Sampling: 8:43 a.m.
Place of Sampling: Tutay, Pinamungajan, Cebu
Water Supply: Deepwell
Date of Release: February 3, 2017

RWT No. : ML 78790

Test Requested	Methodology	Units of Measurement/ Standards	No. of Positive Tubes (out of 5 Tubes)	Result/s	Standard/s	Remarks
Total Coliform	MTFT	MPN/100 mL	0	< 1.1	< 1.1	Passed
Thermotolerant Coliform	MTFT	MPN/100 mL	0	< 1.1	< 1.1	Passed
Heterotrophic Plate Count	Pour Plate	CFU/ mL	-	1	< 500	Passed

* MTFT - Multiple Tube Fermentation Technique

* CFU - Colony Forming Unit

* MPN - Most Probable Number

The result given in this report were obtained at the time of the test and refer only to the particular sample submitted.

References:

Philippine National Standards for Drinking Water, 2007.

Department of Health.

DAO 34 - 35. Department of Environment and Natural Resources.

American Public Health Association (APHA)., 2005.

Standard Methods for the Examination of Water and Wastewater,
21st ed., APHA Washington D.C.

Analysis done by:

Ms. Sherry Lyn Segueria
Lab Analyst

Checked & Certified by:

Ms. Happy Mariel U. Lim
Laboratory Head

PRC License No. 0013262

Approved by:

Mr. Johnjay L. Po
General Manager